



FRISTADS®

**The best way to protect
yourself is to have multiple
layers of garments.**

Certified electric arc garment combinations

Open arc EN 61482-1-1
Box test EN 61482-1-2

Certified electric arc garment combinations.



FRISTADS

Material MOFN

Material ATHS



7026 / 301315 7029 / 301316

+



4174 / 119921 4176 / 120929 4175 / 119922 4275 / 122195 3074 / 121115

=

Open Arc EN 61482-1-1
ELIM 26 cal/cm²
ATPV 30 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA



7027 / 301314

+



2074 / 109417 2075 / 109420 2176 / 121355 2144 / 121354 1075 / 109419 2777 / 126518 2775 / 122196 2776 / 122197

=

Open Arc EN 61482-1-1
ELIM 26 cal/cm²
ATPV 30 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA



7027 / 301314 7026 / 301315 7029 / 301316

+



8174 / 130666 8175 / 125893

=

Open Arc EN 61482-1-1
ELIM 26 cal/cm²
ATPV 30 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material TFLH

Material ATHS



7072 / 111842 7077 / 125041 7098 / 129523 7097 / 129522

+



4174 / 119921 4176 / 120929 4175 / 119922 4275 / 122195 3074 / 121115

=

Open Arc EN 61482-1-1
ELIM 23 cal/cm²
EBT 26 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material TFL

Material ATHS



7359 / 131147 7360 / 131149 7107 / 133268 7357 / 131146 7358 / 131148 7108 / 133269

+



4174 / 119921 4176 / 120929 4175 / 119922 4275 / 122195 3074 / 121115

=

Open Arc EN 61482-1-1
ELIM 27 cal/cm²
ATPV 33 cal/cm²

Certified electric arc garment combinations.



FRISTADS

Material **MFRN**

Material **ATHS**



Open Arc EN 61482-1-1
= ELIM 39 cal/cm²
EBT 45 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **MOFN**

Material **SFLA, SFLH**

Material **ATHS**



Open Arc EN 61482-1-1
= ELIM 45 cal/cm²
ATPV 52 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **MOFN**

Material **TFLH**

Material **ATHS**



Open Arc EN 61482-1-1
= ELIM 32 cal/cm²
ATPV 35 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **MOFN**

Material **TFL**

Material **ATHS**



Open Arc EN 61482-1-1
= ELIM 40 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Certified electric arc garment combinations.



FRISTADS

Material **MOFN**

Material **ATHF**



7026 / 301315 7029 / 301316



4160 / 301776
4161 / 301777



Open Arc EN 61482-1-1
ELIM 21 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA



7027 / 301314



2163 / 129519 2263 / 301676 2167 / 129520 2267 / 301677 2507 / 133137
2171 / 129521 2271 / 301678 2164 / 300374



Open Arc EN 61482-1-1
ELIM 21 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA



2162 / 129518 2161 / 129517 1170 / 301782 2168 / 300239 1169 / 301781
2170 / 301780 2169 / 301779

Material **MOFN**

Material **ATS**



7026 / 301315 7029 / 301316



7200 / 114095 7074 / 109425 7051 / 124309 7050 / 124178
7099 / 129524



Open Arc EN 61482-1-1
ELIM 19 cal/cm²
ATPV 21 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **MOFN**

Material **SFLA, SFLH**



7026 / 301315 7029 / 301316



984 / 100581 7076 / 109428



Open Arc EN 61482-1-1
ELIM 30 cal/cm²
EBT 32 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **MOFN**

Material **ATF**



7026 / 301315 7029 / 301316



4073 / 109430 4063 / 122233



Open Arc EN 61482-1-1
ELIM 19 cal/cm²
EBT 27 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Certified electric arc garment combinations.



FRISTADS

Material **MOFN**

Material **FSS**



7026 / 301315 7029 / 301316



4016 / 127669 4019 / 300561 4180 / 300487
4076 / 130238



Open Arc EN 61482-1-1
ELIM 34 cal/cm²
ATPV 34 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA



7027 / 301314



2180 / 300488 1180 / 301463



Open Arc EN 61482-1-1
ELIM 34 cal/cm²
ATPV 34 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **TFLH**

Material **FSS**



7072 / 111842 7077 / 125041
7098 / 129523 7097 / 129522



4016 / 127669 4019 / 300561 4180 / 300487
4076 / 130238



Open Arc EN 61482-1-1
ELIM 36 cal/cm²
ATPV 43 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **TFL**

Material **FSS**



7359 / 131147 7360 / 131149 7107 / 133268
7357 / 131146 7358 / 131148 7108 / 133269



4016 / 127669 4019 / 300561 4180 / 300487
4076 / 130238



Open Arc EN 61482-1-1
ELIM 37 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **ATS**

Material **FSS**



7200 / 114095 7074 / 109425 7051 / 124309 7050 / 124178
7099 / 129524



4016 / 127669 4019 / 300561 4180 / 300487
4076 / 130238



Open Arc EN 61482-1-1
ELIM 33 cal/cm²
ATPV 38 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Certified electric arc garment combinations.



FRISTADS

Material **TFL**

Material **MFRN**



7359 / 131147 7360 / 131149 7107 / 133268
7357 / 131146 7358 / 131148 7108 / 133269



7180 / 301176 7044 / 301317 7181 / 301177



Open Arc EN 61482-1-1
ELIM 31 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **ATS**

Material **ATHR**



7200 / 114095 7074 / 109425 7051 / 124309 7050 / 124178
7099 / 129524



4525 / 134416
4526 / 300563



Open Arc EN 61482-1-1
ELIM 35 cal/cm²
ATPV 40 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **MFRN**

Material **ATHR**



7180 / 301176 7044 / 301317 7181 / 301177



4525 / 134416
4526 / 300563



Open Arc EN 61482-1-1
ELIM 49 cal/cm²
ATPV 53 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Certified electric arc garment combinations.



FRISTADS

Material **MOFN**

Material **FLAM**



7026 / 301315 7029 / 301316



4030 / 100333 4031 / 100334 4584 / 125938 4590 / 125952 3587 / 125953



Open Arc EN 61482-1-1
ELIM 42 cal/cm²
EBT 50 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA



7027 / 301314



2586 / 125941 2584 / 125939 2587 / 125942 2585 / 125940 2589 / 125950 2591 / 125951



Open Arc EN 61482-1-1
ELIM 42 cal/cm²
EBT 50 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA



2030 / 100329 2031 / 100330 0030 / 100328 1585 / 125943 1584 / 126510 2730 / 125954



7027 / 301314 7026 / 301315 7029 / 301316



8030 / 100338 8084 / 125949



Open Arc EN 61482-1-1
ELIM 42 cal/cm²
EBT 50 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **TFL**

Material **FLAM**



7359 / 131147 7360 / 131149 7107 / 133268 7357 / 131146 7358 / 131148 7108 / 133269



4030 / 100333 4031 / 100334 4584 / 125938 4590 / 125952 3587 / 125953



Open Arc EN 61482-1-1
ELIM 48 cal/cm²
ATPV 53 cal/cm²

Material **PFLA**

Material **FLAM**



784 / 100472



4030 / 100333 4031 / 100334 4584 / 125938 4590 / 125952 3587 / 125953



Open Arc EN 61482-1-1
ELIM 22 cal/cm²
ATPV 30 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Certified electric arc garment combinations.



FRISTADS

Material **SFLA, SFLH**

Material **FLAM**



984 / 100581

7076 / 109428

+



4030 / 100333

4031 / 100334

4584 / 125938
4590 / 125952

3587 / 125953

=

Open Arc EN 61482-1-1
ELIM 52 cal/cm²
EBT 55 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA

Material **MFRN**

Material **FLAM**



7180 / 301176

7044 / 301317

7181 / 301177

+



4030 / 100333

4031 / 100334

4584 / 125938
4590 / 125952

3587 / 125953

=

Open Arc EN 61482-1-1
ELIM 50 cal/cm²

Box test EN 61482-1-2
APC 2, 7 kA